



CUSTOMER SERVICE TERMINATION ENCLOSURE

CATALOG NUMBER AND DATA SHEET (TO BE INCLUDED WITH ALL CSTE ORDERS)

CSTE 4846

← Enter Part # HERE

CURRENT RATING	
Code	Current (amperes)
12	1200
16	1600
20	2000
25	2500 Splitter only

VOLTAGE RATING	
Code	Volts
1	120/240
2	120/208
3	347/600
4	600

Enclosure Style	
Code	Style
W	Wall Mount (WM)
P	Pad Mount (PM)

Bus Bar Type	
Code	Bus Bar
M	Metering
S	Splitter

Phase Rating	
Code	Phase
13	Single Phase 3-Wire
33	Three Phase 3-Wire
34	Three Phase 4-Wire

CSTE 4846

FIBERGLASS PAD #3901A

Part #
Description

CUSTOMER LUG SECTION & METER CABINET SELECTION TABLE										
LINE LUGS				LOAD LUGS				GROUND LUGS		
QUANTITY PER PH & NEUTRAL				QUANTITY PER PH & NEUTRAL						
Lug size (MCM)	Single	Twin	Qty.	Lug size (MCM)	Single	Twin	Qty.	Lug size (MCM)	Twin	Qty.
350 (6 to 350)	<input type="checkbox"/>	<input type="checkbox"/>		250 (6 to 250)	<input type="checkbox"/>	<input type="checkbox"/>		250 (6 to 250)	<input type="checkbox"/>	
600 (2 to 600)	<input type="checkbox"/>	<input type="checkbox"/>		350 (6 to 350)	<input type="checkbox"/>	<input type="checkbox"/>				
800 (300 to 800)	<input type="checkbox"/>	<input type="checkbox"/>		600 (4 to 600)	<input type="checkbox"/>	<input type="checkbox"/>				
	<input type="checkbox"/>			800 (350 to 800)	<input type="checkbox"/>	<input type="checkbox"/>				
MANITOBA HYDRO STANDARD PROVISIONS (4) X 2-HOLE NEMA PROVISIONS FOR 750 MCM COMPRESSION LUGS			<input type="checkbox"/> YES <input type="checkbox"/> NO							

NOTES:

- Applications with metering, a Remote Meter Cabinet is req'd except on single phase
- Applications with metering are Suitable from 1200 AMPS to 2000 AMPS
- Applications for Splitter with NO metering are Suitable from 1200 AMPS to 2500 AMPS
- Weight: Approximately 600lbs

906B KING EDWARD STREET
WINNIPEG, MANITOBA, R3H0P4
PH: 204-774-5053, FAX:204-774-5263