



CUSTOMER SERVICE TERMINATION ENCLOSURE
CATALOG NUMBER AND DATA SHEET (TO BE INCLUDED WITH ALL CSTE ORDERS)

CSTE 6060

← Enter Part# HERE

CURRENT RATING	
Code	Current (amperes)
20	2000 (Metering)
25	2500
30	3000
35	3500
40	4000

Enclosure Style	
Code	Style
W	Wall Mount (WM)
P	Pad Mount (PM)

VOLTAGE RATING	
Code	Volts
1	120/240
2	120/208
3	347/600
4	600

Bus Bar Type	
Code	Bus Bar
M	Metering
S	Splitter

Phase Rating	
Code	Phase
13	Single Phase 3-Wire
33	Three Phase 3-Wire
34	Three Phase 4-Wire



FIBERGLASS PAD 3901B

Part #	
Description	

CUSTOMER LUG SECTION & METER CABINET SELECTION TABLE										
LINE LUGS				LOAD LUGS				GROUND LUGS		
QUANTITY PER PH & NEUTRAL				QUANTITY PER PH & NEUTRAL						
Lug size (MCM)	Single	Twin	Qty.	Lug size (MCM)	Single	Twin	Qty.	Lug size (MCM)	Twin	Qty.
350 (6 to 350)	<input type="checkbox"/>	<input type="checkbox"/>		350 (6 to 350)	<input type="checkbox"/>	<input type="checkbox"/>		250 (6 to 250)	<input type="checkbox"/>	
600 (2 to 600)	<input type="checkbox"/>	<input type="checkbox"/>		600 (2 to 600)	<input type="checkbox"/>	<input type="checkbox"/>				
800 (300 to 800)	<input type="checkbox"/>	<input type="checkbox"/>		800 (300 to 800)	<input type="checkbox"/>	<input type="checkbox"/>				
MANITOBA HYDRO STANDARD PROVISIONS (4) X 2-HOLE NEMA PROVISIONS FOR 750 MCM COMPRESSION LUGS			<input type="checkbox"/> YES <input type="checkbox"/> NO	NOTE: REMOTE METER CABINET IF REQUIRED WILL BE SUPPLIED LOOSE						<input type="checkbox"/> YES/NO

NOTES:

1. Applications with metering, a Remote Meter Cabinet is req'd except on single phase 2. Applications with metering are Suitable from 2000 AMPS to 4000 AMPS 3. Applications for Splitter with NO metering are Suitable from 2500 AMPS to 4000 AMPS 4. Weight: Apporximately 800 lbs	906B KING EDWARD STREET WINNIPEG, MANITOBA, R3H0P4 PH: 204-774-5053, FAX:204-774-5263
---	---